



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA140073

Date of Issue: 22 January 2014

Class Description: Non-Declared
Product Description: PV Grid-interactive Inverter

Additional Models

iMars BG25KTR

iMars BG20KTR

Description

Similar to iMars BG30KTR except rated input Max continuous current: 30A×2, Isv: 33A×2 and output Max 40A, Max 25kVA.


Similar to iMars BG30KTR except rated input Max continuous current: 26A×2, Isv: 29A×2 and output Max 32A, Max 20kVA.

A handwritten signature in dark ink, appearing to be 'L. G.', written over a horizontal line.

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

JAS-ANZ



For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

www.jas-anz.org/register

140073/2