



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA152358

Date of Issue: 30 November 2015

Class Description: Non-Declared
Product Description: PV: Grid-interactive Inverter

Additional Models

Description

iMars BG15KTR

Similar to iMars BG17KTR except rated:
Input: 1000Vdc Max, MPPT voltage range 180-800Vdc, Max 2x21A, Isc PV: 2x23.5A
Output: 3/N/PE 230/400V~ 50Hz, Max 24.1A 15kVA

iMars BG12KTR

Similar to iMars BG17KTR except rated:
Input: 1000Vdc Max, MPPT voltage range 180-800Vdc, Max 2x19A, Isc PV: 2x21A
Output: 3/N/PE 230/400V~ 50Hz, Max 19.3A 12kVA

iMars BG10KTR

Similar to iMars BG17KTR except rated:
Input: 1000Vdc Max, MPPT voltage range 180-800Vdc, Max 2x19A, IscPV: 2x21A
Output: 3/N/PE 230/400V~ 50Hz, Max 16.1A 10kVA

iMars BG8KTR

Similar to iMars BG17KTR except rated:
Input: 1000Vdc Max, MPPT voltage range 180-800Vdc, Max 2x14A, Isc PV: 2x15.5A
Output: 3/N/PE 230/400V~ 50Hz, Max 12.8A 8kVA

iMars BG6KTR

Similar to iMars BG17KTR except rated:
Input: 1000Vdc Max, MPPT voltage range 180-800Vdc, Max 2x11A, IscPV: 2x12.5A
Output: 3/N/PE 230/400V~ 50Hz, Max 9.6A 6kVA

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 01-12-15 152358/2a
Correction to ratings.